



NOTES:

1. DOUBLE CHECK VALVE ASSEMBLY SHALL MEET REQUIREMENTS OF THE AWWA "ACCEPTED PROCEDURE AND PRACTICE IN CROSS-CONNECTION CONTROL" MANUAL.
2. DEVICES MUST BE ON STATE DEPT OF SOCIAL AND HEALTH SERVICES LIST OF "APPROVED CROSS-CONNECTION CONTROL DEVICES".
3. METER BOX SIZE SHOULD BE THE SIZE SPECIFIED FOR THE METER SIZE EQUIVALENT TO THE BACKFLOW PREVENTOR SIZE.

APPROVED: SCOTT THOMASSON

REV. DATE: NOV. 01, 2005

WATER/WASTEWATER DIVISION



STANDARD DETAILS

**IRRIGATION/RESIDENTIAL FIRE
BACKFLOW PREVENTOR (3/4" - 2")**

FILE	SD711.DGN	DRAWING NO.	711
------	-----------	-------------	-----